Energy performance certificate (EPC)			
17 Badsworth Gardens NEWBURY RG14 6PH	Energy rating	Valid until:	30 June 2034
		Certificate number:	6900-3489-0822-1323-3643
Property type	G	Ground-floor flat	
Total floor area	1	29 square metres	

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlordguidance).

Energy rating and score

This property's energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.

Score	Energy rating		Current	Potential
92+	Α			
81-91	В			
69-80	С		74 C	75 C
55-68	D			
39-54	I	Ξ		
21-38		F		
1-20		G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Timber frame, as built, insulated (assumed)	Good
Window	Fully double glazed	Average
Main heating	Electric underfloor heating	Average
Main heating control	Temperature zone control	Good
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in 14% of fixed outlets	Poor
Roof	(another dwelling above)	N/A
Floor	Suspended, insulated (assumed)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 234 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£1,811 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £104 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 6,861 kWh per year for heating
- 2,023 kWh per year for hot water

Impact on the envir	ronment	This property produces	5.1 tonnes of CO2	
This property's environmer D. It has the potential to be		This property's potential production	5.0 tonnes of CO2	
Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.		You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.		
Carbon emissions		These ratings are based of about average occupancy	and energy use.	
An average household produces	6 tonnes of CO2	People living at the property may use differ amounts of energy.		

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Low energy lighting	£60	£104

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ellise Bloor-White
Telephone	01189770690
Email	epc@nichecom.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/028023
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party	
Date of assessment	28 June 2024	
Date of certificate	1 July 2024	
Type of assessment	RdSAP	