

Energy performance certificate (EPC)

| | | |
|---|---------------------------|--|
| 5 Kings Court Old Bolingbroke SPILSBY PE23 4HR | Energy rating B | Valid until: 10 April 2034 |
| | | Certificate number: 0330-2111-1340-2804-4671 |

| | |
|------------------|-------------------|
| Property type | Detached house |
| Total floor area | 156 square metres |

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's energy rating is B. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+ | A | | |
| 81-91 | B | 87 B | 89 B |
| 69-80 | C | | |
| 55-68 | D | | |
| 39-54 | E | | |
| 21-38 | F | | |
| 1-20 | G | | |

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature | Description | Rating |
|----------------------|--|-----------|
| Wall | Cavity wall, as built, insulated (assumed) | Very good |
| Roof | Pitched, 300 mm loft insulation | Very good |
| Roof | Roof room(s), insulated (assumed) | Very good |
| Window | Fully double glazed | Good |
| Main heating | Boiler and radiators, oil | Average |
| Main heating control | Programmer, room thermostat and TRVs | Good |
| Hot water | From main system | Average |
| Lighting | Low energy lighting in all fixed outlets | Very good |
| Floor | Solid, insulated (assumed) | N/A |
| Secondary heating | Room heaters, wood logs | N/A |

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO₂. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Biomass secondary heating
- Solar photovoltaics

Primary energy use

The primary energy use for this property per year is 45 kilowatt hours per square metre (kWh/m²).

▶ [About primary energy use](#)

Additional information

Additional information about this property:

- PVs or wind turbine present on the property (England, Wales or Scotland)
The assessment does not include any feed-in tariffs that may be applicable to this property.

How this affects your energy bills

An average household would need to spend **£1,297 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £56 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 9,783 kWh per year for heating
- 2,906 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

| | |
|---|-------------------------------|
| An average household produces | 6 tonnes of CO ₂ |
| This property produces | 2.4 tonnes of CO ₂ |
| This property's potential production | 2.1 tonnes of CO ₂ |

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

▶ [Do I need to follow these steps in order?](#)

Step 1: Solar water heating

Typical installation cost £4,000 - £6,000

Typical yearly saving £56

Potential rating after completing step 1

89 B

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

[Find ways to save energy in your home](#)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

| | |
|-----------------|--|
| Assessor's name | Joanne McGinn |
| Telephone | 07531 350581 |
| Email | jmsurveyors@live.co.uk |

Contacting the accreditation scheme


If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

| | |
|----------------------|--|
| Accreditation scheme | Elmhurst Energy Systems Ltd |
| Assessor's ID | EES/014779 |
| Telephone | 01455 883 250 |
| Email | enquiries@elmhurstenergy.co.uk |

About this assessment

| | |
|------------------------|------------------|
| Assessor's declaration | No related party |
| Date of assessment | 9 April 2024 |
| Date of certificate | 11 April 2024 |

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748  (Monday to Friday, 9am to 5pm).

Certificate number

[8090-9689-7829-5626-7073](/energy-certificate/8090-9689-7829-5626-7073) (/energy-certificate/8090-9689-7829-5626-7073) 

Expired on

29 October 2023

Certificate number

[8672-6635-9670-0854-0922](/energy-certificate/8672-6635-9670-0854-0922) (/energy-certificate/8672-6635-9670-0854-0922) 

Expired on

23 May 2022

[Help \(/help\)](/help) [Accessibility \(/accessibility-statement\)](/accessibility-statement) [Cookies \(/cookies\)](/cookies)

[Give feedback \(https://forms.office.com/e/hUnC3Xq1T4\)](https://forms.office.com/e/hUnC3Xq1T4) [Service performance \(/service-performance\)](/service-performance)

OGL

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ht \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/)