

# Energy performance certificate (EPC)

4, Alder Road NEATH SA11 3NY	Energy rating <b>E</b>	Valid until: 13 June 2027
		Certificate number: 0155-2827-7464-9393-9395

Property type Semi-detached house

Total floor area 86 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy rating and score

This property's energy rating is E. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	<b>A</b>		
81-91	<b>B</b>		
69-80	<b>C</b>		79 C
55-68	<b>D</b>		
39-54	<b>E</b>	51 E	
21-38	<b>F</b>		
1-20	<b>G</b>		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, insulated at rafters	Poor
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	Low energy lighting in 27% of fixed outlets	Average
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

## Primary energy use

The primary energy use for this property per year is 367 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [About primary energy use](#)

## Additional information

Additional information about this property:

- Cavity fill is recommended

## How this affects your energy bills

An average household would need to spend **£1,223 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £473 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2017** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 14,988 kWh per year for heating
- 2,161 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

## Carbon emissions

**An average household produces**

6 tonnes of CO<sub>2</sub>

**This property produces**

5.6 tonnes of CO<sub>2</sub>

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Changes you could make

► [Do I need to follow these steps in order?](#)

## Step 1: Cavity wall insulation

Typical installation cost	£500 - £1,500
Typical yearly saving	£266
Potential rating after completing step 1	<b>61 D</b>

## Step 2: Floor insulation (solid floor)

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£55
Potential rating after completing steps 1 and 2	<b>63 D</b>

## Step 3: Low energy lighting

Typical installation cost	£40
Typical yearly saving	£35
Potential rating after completing steps 1 to 3	<b>65 D</b>

## Step 4: Heating controls (room thermostat)

Typical installation cost	£350 - £450
Typical yearly saving	£35
Potential rating after completing steps 1 to 4	<b>66 D</b>

## Step 5: Replace boiler with new condensing boiler

Typical installation cost	£2,200 - £3,000
Typical yearly saving	£56
Potential rating after completing steps 1 to 5	<b>68 D</b>

## Step 6: Flue gas heat recovery device in conjunction with boiler

Typical installation cost	£400 - £900
Typical yearly saving	£26

---

Potential rating after completing steps 1 to 6

69 C

---

## Step 7: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£5,000 - £8,000

Typical yearly saving

£289

Potential rating after completing steps 1 to 7

79 C

---

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

[Find ways to save energy in your home](#)

---

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Brian Cullen
Telephone	07866493818
Email	<a href="mailto:brian_cullen@hotmail.co.uk">brian_cullen@hotmail.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO019988
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

## About this assessment

Assessor's declaration	No related party
Date of assessment	13 June 2017
Date of certificate	14 June 2017
Type of assessment	▶ <a href="#">RdSAP</a>

---

# Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/hUnC3Xq1T4\)](https://forms.office.com/e/hUnC3Xq1T4) [Service performance \(/service-performance\)](#)

## **OGL**

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ht \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/)