

Energy performance certificate (EPC)

Bryn Tiron Llanallgo MOELFRE LL72 8HB	Energy rating E	Valid until: 22 February 2026
		Certificate number: 8607-1774-6229-9827-1263

Property type

Mid-terrace house

Total floor area

87 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be A.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Poor
Wall	Cavity wall, as built, partial insulation (assumed)	Average
Roof	Pitched, no insulation	Very poor

Feature	Description	Rating
Roof	Flat, limited insulation (assumed)	Poor
Window	Fully double glazed	Average
Main heating	Electric storage heaters	Average
Main heating control	Automatic charge control	Average
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in 20% of fixed outlets	Poor
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 595 kilowatt hours per square metre (kWh/m²).

► [What is primary energy use?](#)

Additional information

Additional information about this property:

- Dwelling may be exposed to wind-driven rain

Environmental impact of this property

This property's current environmental impact rating is F. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year. CO₂ harms the environment.

An average household produces

6 tonnes of CO₂

This property produces

8.7 tonnes of CO₂

This property's potential production

0.6 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

Improve this property's energy rating

Follow these steps to improve the energy rating and score.

▶ [Do I need to follow these steps in order?](#)

Step 1: Increase loft insulation to 270 mm

Typical installation cost

£100 - £350

Typical yearly saving

£347

Potential rating after completing step 1

57 | D

Step 2: Cavity wall insulation

Typical installation cost

£500 - £1,500

Typical yearly saving

£34

Potential rating after completing steps 1 and 2

59 | D

Step 3: Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£141

Potential rating after completing steps 1 to 3

Step 4: Floor insulation (solid floor)

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£47

Potential rating after completing steps 1 to 4

66 | D

Step 5: Low energy lighting

Typical installation cost

£40

Typical yearly saving

£39

Potential rating after completing steps 1 to 5

68 | D

Step 6: High heat retention storage heaters

Typical installation cost

£2,000 - £3,000

Typical yearly saving

£200

Potential rating after completing steps 1 to 6

75 | C

Step 7: Solar water heating

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£57

Potential rating after completing steps 1 to 7

77 | C

Step 8: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£5,000 - £8,000

Typical yearly saving

£311

Potential rating after completing steps 1 to 8

87 | B

Step 9: Wind turbine

Typical installation cost

£15,000 - £25,000

Typical yearly saving

£590

Potential rating after completing steps 1 to 9

110 | A

Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

Estimated yearly energy cost for this property

£1448

Potential saving if you complete every step in order

£865

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used
Space heating	11670 kWh per year
Water heating	4480 kWh per year

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Loft insulation	4058 kWh per year
Cavity wall insulation	402 kWh per year
Solid wall insulation	1651 kWh per year

Saving energy in this property

[Find ways to save energy in your home.](#)

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Mark Banham

Telephone

01484 773272

Email

markbanham@psgenergy.co.uk

Accreditation scheme contact details**Accreditation scheme**

Stroma Certification Ltd

Assessor ID

STRO006474

Telephone

0330 124 9660

Email

certification@stroma.com

Assessment details**Assessor's declaration**

No related party

Date of assessment

23 February 2016

Date of certificate

23 February 2016

Type of assessment

▶ [RdSAP](#)

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.