



EMERGENCY LIGHTING CERTIFICATE
CERTIFICATE No: EMS-20221213104633

This is to certify that the emergency lighting installation at the address below complies with the requirements of BS 5266-1:2016

4-6 Wood Street
Bolton
BL1 1EB

The following work was carried out by

Company issuing this Certificate

Electrical Installation Contractors Ltd
Unit 24, Pilsworth Way
Bury
England
BL98RE

01615118748

sales@e-i-c.co.uk

CPS Enrolment No: D609025

Issued on

22/09/2022

Inspected by

Ryan Burton

R.Burton

Reviewed by

Ryan Burton

R.Burton

Recommended re-test

22/09/2023

Certificate generated by electroform® certification software 2023 | www.electraform.co.uk

DETAILS OF THE CLIENT

Client name

Peter Wu

Town

Bolton

Postcode

BL1 1EB

Telephone

-

Address

4-6 Wood Street

County

-

Mobile

-

Email

Peter.wu@thechinesebuffet.com

DETAILS OF THE EMERGENCY LIGHTING INSTALLATION

Occupier name

Communal Area

Address

4-6 Wood Street

Town

Bolton

County

-

Postcode

BL1 1EB

Telephone

-

Installation is

 New An addition An alteration

Installation description

11x Emergency Lights within Communal Areas of 4-6 Wood Street

DETAILS OF DEVIATIONS FROM THE STANDARD

Deviation Number	Declaration (Design Installation or Verification)	Clause Number	Details of deviations

RELATED REFERENCE DOCUMENTS

This certificate is only valid when accompanied by current:

- Signed declaration(s) of design, installation and verification, as applicable (see overleaf).
- Photometric design data. This can be in any of the following formats but in all cases appropriate de-rating factors must be used and identified to meet worst case requirements.

- Authenticated spacing data such as ICEL 1001 registered tables**
- Calculations as detailed in Annex G and CIBSE/SLL Guide LG12***
- Appropriate computer print of results

- Test log book

* New works are deemed to be small when involving installations up to 25 new emergency lighting luminaires.

** Available from Industry Committee for Emergency Lighting, Ground floor, Westminster Tower, 3 Albert Embankment, London, SE17SL.

*** Available from Chartered Institution of Building Services Engineers, Delta House, 222 Balham High Road, London SW129BS.

Essential related reference documents accompanying this certificate

Vision Architectural - DRWG N0: (10).001 / (10).002 / (10).003 / (10).004

DECLARATION OF CONFORMITY

In consequence of acceptance of the appended declarations I/we hereby declare that the emergency lighting system installation, or part thereof, at the above premises conforms, to the best of my/our knowledge and belief, to the appropriate recommendations given in BS5266-1:2016, Emergency lighting - Part 1: Code of practice for the emergency lighting of premises, BSEN 1838:2013 Lighting applications - Emergency lighting and BSEN 50172:2004, Emergency escape lighting systems, as set out in the accompanying declarations, except as stated below/overleaf.

Completed by

Name

Ryan Burton

Signature

RB

Position

Electrician

Date

22/09/2022

Certificate authorised by

Name

Ryan Burton

Signature

RB

Position

Electrician

Date

22/09/2022

NEXT INSPECTION

I / We, recommend that this installation is further inspected and tested no later than



22/09/2023

CHECKLIST REPORT

<i>Designer</i>	D	<i>Installer</i>	I	<i>Verifier</i>	V
-----------------	----------	------------------	----------	-----------------	----------

Any failures of conformity should be covered by a deviation and recorded under the appropriate declaration on the Completion Certificate

BS 5266-1:2016 Clause Reference	Engineer Function	Recommendations	System conforms
Check of categories and documentation			
4.2	D,V	Are plans of the system available and correct?	YES
6.7	D,V	Has the system been designed for the correct mode of operation category?	YES
6.7	D,V	Has the system been designed for the correct emergency duration period?	YES
Clause11	D,V	Is a completion certificate available with the photometric design data?	YES
Clause11	D,I,V	Is a test log book available and are the entries up to date?	YES
Check of design			
4.1:5.2.8	D,I,V	Are the correct areas of the premises covered to meet the risk assessment?	YES
5.2.8	D,I,V	Are all hazards identified by the risk assessment covered?	YES
5.2.8	D,I,V	Are there luminaires sited at the "points of emphasis"?	YES
5.2.2	D,I,V	Is the spacing between luminaires compliant with authenticated spacing or design data?	YES
5.2.9	D,I,V	Are the emergency exit signs and escape route direction signs correct and the locations of other safety signs to be illuminated under emergency conditions identified?	YES
6.1	D,I,V	Do all non-maintained luminaires operate on local final circuit failure?	YES
6.3	D,V	Is there illumination from at least two luminaires in each compartment?	YES
6.4	I,V	Are luminaires at least 2m above the floor and avoiding smoke reservoirs?	YES
5.8.2.5;5.8.2.6	D,V	Are additional luminaires located to cover toilets, lifts, plant-rooms etc?	YES
Check of the quality of the system components and installation			
6.7	D,I,V	Do the luminaires conform to BSEN 60598-2-22?	YES
6.7	D,I,V	Do any converted luminaires conform to BSEN 60598-2-22?	YES
6.7	D,I,V	Do luminaires have a suitable degree of protection for their location?	YES
Clause 8	I,V	Does the installation conform to the good practice defined in BS 7671?	YES
8.2.1	D,I,V	For centrally powered systems, is the wiring fire resistant?	YES
8.2.12	D,I,V	Are any plugs or sockets protected against unauthorized use?	YES
Test facilities			
8.3.3	D,V,I	Are the test facilities suitable to test function and duration?	YES
8.3.3	D,I,V	Are the test facilities safe to operate and do not isolate a required service?	YES
8.3.3	D,I,V	Are the test facilities clearly marked with their function?	YES
8.3.3	D,I,V	If an automatic test system is installed, does it conform to BSEN 62034?	YES
10.7	D,V	Are the user's staff trained and able to operate the test facilities and record the test results correctly?	YES

BS 5266-1:2016 Clause Reference	Engineer Function	Recommendations	System conforms
Final acceptances to be conducted at completion			
Clause 12	D,I,V	Does the system operate correctly when tested?	YES
10.7	D,I,V	Has adequate documentation been provided to the user?	YES
10.7	D,I,V	Is the user aware of action they should take in the event of a test failure?	YES
COMMENTS			
ACTION RECOMMENDED - (DEVIATIONS TO BE RECORDED ON THE COMPLETION CERTIFICATE)			
-			
COMPANY ISSUING THIS CERTIFICATE			
Trading title	Postcode	Company email	
Electrical Installation Contractors Ltd	BL98RE	sales@e-i-c.co.uk	
Address	Telephone no	Website	
Unit 24, Pilsworth Way	01615118748	www.e-i-c.co.uk	
Town	Mobile number		
Bury	-		
County	Enrolment no		
England	D609025		
Name of competent person making the declaration of conformity			
Name (Capitals)	Signature	Date	
Ryan Burton		22/09/2022	

Certificate produced by electroform[®] based on the MODEL FORM from BS5266:2016