

Domestic Landlord / Homeowner Gas Safety Record



Date:	6th December 2023	Ref:	
Gas Safe Reg No:	565679	Serial no:	GAUK00995662

Details of Registered Business		Details of Landlord / Homeowner (or agent where appropriate)		Details of Site	
Name:	R&R Plumbing & Heating Bolton Ltd.	Name:	Campus Cribs Estate Agents	Name:	
Address:	16 Arnold Street	Address:	92 Great Moor Street	Address:	69 Hastings Road
			Great Moor Street		
	Bolton		Bolton		Bolton
	Lancashire		Lancashire		Lancashire
Postcode:	BL1 3HD	Postcode:	BL3 6DS	Postcode:	BL14NG
Contact Number:	07718534333	Contact Number:	+44 1204 535400	Contact Number:	07934452839

Appliance Details								Final check results		
	Location	Type	Manufacturer	Model	Owned by Landlord	Appliance Inspected?	Flue Type			
1	Back Dining Room	Combi Boiler	Alpha	E tec 28	Yes	Yes	RS-FF	Outcome of gas tightness test	Pass	
Inspection Details								Is the main protective equipotential bonding satisfactory?	No	
	Operating Pressure (mbars) or heat input (kW/h)	Safety devices operating correctly?	Satisfactory Ventilation?	Visual condition of flue & termination.	Flue operation checks.	Combustion analyser reading.	Was appliance serviced?	Is appliance safe to use?	Is the emergency control accessible?	Yes
1	27.8 kW/h	Yes	Yes	Pass	Pass	0.0009	No	Yes	Satisfactory visual inspection of gas installation pipework?	Yes
									CO alarm fitted and working?	Yes
Notes										

	Defects Identified	Remedial Work Details	Label & Warning Notice	Combustion Performance Readings					
				Low			High		
				CO	CO ²	Ratio	CO	CO ²	Ratio
1	None	None	No	11	8.94	0.0002	88	9.61	0.0009

Next Inspection Is Due Before: 6th December 2024	Record Issued By:				Received By:			
	Signature:				Signature:			
	Gas Engineer	Mohammed Karmadi			Name	Mr Callum Sherratt		
Gas Safe Licence	5550933	Date	6th December 2023	Position	Tenant	Date	6th December 2023	

This record can be used to document the outcome of checks and tests required by The Gas Safety (Installation and Use) Regulations 1998 as amended by the Gas Safety (Installation and Use) (Amendment) Regulations 2018. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate. Unless specifically recorded no detailed inspection of the flue lining, construction or integrity has been performed. Registered Business / engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.